



By Appointment to
Her Majesty the Queen
Manufacturers of Fire Detection
& Alarm Products
Apollo Fire Detectors Ltd
Hampshire

Date Of Issue –18th April 2011
EMC Directive 2004/108/EC

36 Brookside Road, Havant,
Hampshire, PO9 1JR, UK

Tel: +44 (0)23 9249 2412
Fax: +44 (0)23 9249 2754

Email: sales@apollo-fire.co.uk
Web: www.apollo-fire.co.uk



APOLLO FIRE DETECTORS LTD

DECLARATION OF CONFORMITY

This document is a declaration that the product family identified below conforms with the essential protection requirements that have been specified in the European Directive on Electromagnetic Compatibility 2004/108/EC. This Directive has been enacted into UK law by the Statutory Instrument No. 2006:3418, The Electromagnetic Compatibility Regulations.

Product family	Alarmsense
Product description	Part Number
Optical Smoke Detector	55000-390
Integrated Optical Smoke Detector	55000-391
Heat Detector (A1R)	55000-190
Heat Detector (CS)	55000-193
Base	45681-244
Alarm Relay	55000-835
MiniDisc Remote Indicator	53832-070
Manual Call Point	55100-894
Sounder Base	45681-510
Sounder Beacon Base	45681-509
Open Area Sounder Beacon	55000-017
Open Area Sounder	55000-018
Open Area Beacon	55000-035
Open Area Base	45681-523

The products are manufactured at the premises of Apollo Fire Detectors Ltd.,36 Brookside Road, Havant, Hampshire, England PO9 1JR.

The part number printed on the product includes a three letter suffix that defines the product packing requirements, compliance with the essential requirements of the EMC Directive are not effected.

The assessment of conformity has been made using the Standards Route To Compliance. The standards that the products are compliant with are listed below.

- 1 BS EN 61000-6-3: 2001 Electromagnetic compatibility - Generic emission standard.
Residential, commercial and light industry
- 2 BS EN 50130-4:1996 Alarm Systems Part 4 Electromagnetic compatibility
(Incorporating Amendment No. 1 & 2) Product family standard : Immunity requirements for components of fire, intruder and social alarm systems

This declaration is made for and on behalf of Apollo Fire Detectors by the Conformance Manager, Mr C. Gare-Mogg, who has been designated as a responsible person for the purpose of the Regulations.

Signature Mr C. Gare-Mogg
A HALMA COMPANY

