

# Declaration of Performance No. 360-3514-0199 REV 04

Declaration of Performance according to the Construction Products Regulation EU No. 305/2011

1. Unique identification code of the product type	Model(s): Stratos-HSSD2, LaserSense HSSD2(9-30621, 9-30706, FHSD8200-XX)  Brand(s): AirSense;Edwards
2. Intended use/es	Aspirating smoke detectors for use in fire detection and fire alarm systems installed in buildings
3. Manufacturer	UTC CCS Manufacturing Polska sp. z o.o. ul. Kolejowa 24, 39 - 100 Ropczyce, Poland
4. Authorized representative	UTC Fire & Security B.V., Kelvinstraat 7, NL-6003 DH Weert, The Netherlands
5. System or systems of AVCP	System 1
6a. Harmonised standard/s: Notified body/ies:	EN 54-20: 2006 0832 - BRE
6b. European Assessment Document: European Technical Assessment: Technical Assessment Body: Notified body/ies:	Not applicable

## 7. Declared performances:

### Aspirating smoke detectors EN54-20


Essential characteristics	Performance	Harmonized technical specification
Nominal activation conditions/sensitivity, response delay (response time), performance under fire conditions	PASS	EN 54-20: 2006
Operational reliability	–	–
Tolerance to supply voltage	PASS	EN 54-20: 2006
Durability of operational reliability, Temperature resistance	PASS	EN 54-20: 2006
Durability of operational reliability, Vibration resistance	PASS	EN 54-20: 2006
Durability of operational reliability, Electrical stability	PASS	EN 54-20: 2006
Durability of operational reliability, Humidity resistance	PASS	EN 54-20: 2006
Durability of operational reliability, Corrosion resistance	PASS	EN 54-20: 2006

## 8. Appropriate Technical Documentation and/or Specific Technical Documentation:

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by::

Jose M. Mendez Segui, Technology Manager,  
Verge de Guadalupe 3, Esplugues de Llobregat  
08950, Barcelona, Spain



At: Esplugues de Llobregat

On: Nov 06<sup>th</sup>, 2015

Regulation (EU) No. 305/2011 CPR Supplementary CE marking information



Identification of the Certification Body: 0832

Manufacturer: UTC CCS Manufacturing Polska sp. z o.o.

ul. Kolejowa 24, 39 - 100 Ropczyce, Poland

Last two digits of year CE mark was first placed: 15

Declaration of Performance (DoP) Number: 360-3514-0199 REV 04

EN 54-20:2006,

Unique identification of product type: See the product label for the product documentation part number and revision.

Intended use: See DoP point 2.

Essential characteristics: See DoP point 7.

EN: Get this document in your language from: / BG: Вземете този документ на български език от / CZ: Získat tento dokument ve Vašem jazyce od: / DA: Få dette dokument på dit sprog fra: / NL: Krijg dit document in uw taal van: / ET: Dokumendi eestikeelse versiooni leiata siit: / ES: Obtenga este documento en su idioma de: / FI: Hanki tämä asiakirja kielelläsi: / FR: Obtenez ce document dans votre langue de: / DE: Sie erhalte das Dokument in Ihrer Sprache von: / EL: Μπορείτε να παραλάβετε το έγγραφο στη γλώσσα σας από: / HU: A dokumentum megvásárolható a kívánt nyelven: / IT: Ottieni questo documento nella tua lingua da: / LV: legūstiet šo dokumentu savā valodā no: / LT: Gauti šį dokumentą jūsų kalba iš: / PL: Pobierz ten dokument w swoim języku z: / PT: Obtenha este documento no seu idioma a partir: / RO: Puteti obtine acest document in limba dumneavoastra de la: / SK: Získať tento dokument vo Vašom jazyku od: / SL: Spravi ta dokument v vašem jeziku od: / SV: Få detta dokument på ditt språk från:

<http://www.utcssecurityproducts.eu/dop/>

[DoP.Requests@fs.utc.com](mailto:DoP.Requests@fs.utc.com)

© 2015 UTC Fire & Security. All rights reserved