



By Appointment to  
Her Majesty The Queen  
Manufacturers of Fire Detection & Alarm Products  
Apollo Fire Detectors Limited  
Hampshire



Date of Issue – 08 February 2021

**EU DECLARATION OF CONFORMITY**

1. Object of the Declaration of Conformity:

**Product Family: Manual Call Points**

Part Number	Product Description
SA5900-908**	Intelligent Manual Call Point with Short Circuit Isolator - Red
SA5900-903**	Intelligent Manual Call Point with Short Circuit Isolator - White
SA5900-904**	Intelligent Manual Call Point with Short Circuit Isolator - Yellow
SA5900-905**	Intelligent Manual Call Point with Short Circuit Isolator - Blue
SA5900-906**	Intelligent Manual Call Point with Short Circuit Isolator - Green
SA5900-907**	Intelligent Manual Call Point with Short Circuit Isolator - Orange
SA5900-100	Intelligent DIN Manual Call Point
SA5900-928	Intelligent Marine Manual Call Point with Short Circuit Isolator - Red
SA5900-011	Dual Switch Manual Call Point - Green
58200-950	Intelligent Waterproof Manual Call Point - Red
58200-951	Intelligent Waterproof Manual Call Point with Isolator - Red
55200-940	Intelligent Waterproof Manual Call Point I.S. - Red
55100-940*	Intelligent I.S. Manual Call Point – Red
55100-942*	Intelligent I.S. Manual Call Point - Yellow
55200-003	Waterproof Manual Call Point – Conventional - Red
55100-905*	Manual Call Point - Red
55100-908*	Manual Call Point with Isolator - Red
58100-905*	Manual Call Point with Isolator - Red
58100-908*	Manual Call Point with Isolator - Red
58100-910*	Manual Call Point - Red
58100-927*	Manual Call Point – Yellow
58100-950*	Waterproof Manual Call Point - Red
58100-951*	Waterproof Manual Call Point with Isolator - Red

Apollo Fire Detectors Limited

A HALMA COMPANY

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

[www.apollo-fire.co.uk](http://www.apollo-fire.co.uk)

Apollo Fire Detectors Ltd. Registered in England No. 1483208

Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB 339 0553 54



Assessed to ISO 9001:2015  
Cert:LPCB ref 010

Assessed to ISO 14001:2015  
Cert:LPCB ref 010 EMS

Cert:LPCB ref 010

58100-953*	Waterproof Manual Call Point – Yellow – With Isolator
58100-970**	Discovery Marine Manual Call Point
58100-971**	Discovery Marine Manual Call Point - Isolator
58100-976**	Discovery Marine Manual Call Point - Outdoor - Isolator
55400-894	AlarmSense Indoor Manual Call Point - Red
55100-894*	AlarmSense Indoor Manual Call Point - Red

2. These products are manufactured at the premises of Apollo Fire Detectors Limited, 36 Brookside Road, Havant, Hampshire, England PO9 1JR/

Items marked with an “\*\*” KAC Alarm Company Limited, KAC House, Thornhill Road, North Moons Moat, Redditch, B98 9ND, UK

Items marked with “\*\*\*” Approved for manufacture at both Apollo Fire Detectors Limited, 36 Brookside Road, Havant, Hampshire, England PO9 1JR or Apollo (Beijing) Fire Products Co, Ltd, Block A5 Jinghai Industrial Park, No.156 Jinghai Fourth Road Beijing Economic-Technological Development Area, Beijing, China, 100176

3. This declaration is issued under the sole responsibility of the manufacturer.
4. The object of the declaration described above is in conformity with the relevant Union harmonization legislation:
- 2014/30/EU      EMC Directive  
2011/65/EU      Restriction of the use of certain hazardous substances in electrical and electronic equipment (RoHS)
5. References to the relevant harmonized standards used or references to the specifications in relation to which conformity is declared:

BS EN 61000-6-3: 2007+A1: 2011      Electromagnetic compatibility (EMC). Generic standards. Emission standard for residential, commercial and light-industrial environments

BS EN 50130-4:2011+A1: 2014      Alarm systems. Electromagnetic compatibility. Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems

This declaration is made for and on behalf of Apollo Fire Detectors by the Technical Director, Mr. Karl Westhead, who has been designated as the responsible person for the purpose of the Regulations.



Signature .....Mr. Karl Westhead – Technical Director

DN 4 v10

