



CERTIFICATE OF CONSTANCY OF PERFORMANCE

0051-CPR-2827

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation, or CPR), this Certificate applies to the construction product

Product: **VOICE ALARM CONTROL AND INDICATING EQUIPMENT WITH INTEGRATED POWER SUPPLY EQUIPMENT**
Models: **PREVIDIA-VOX; PREVIDIA-VOXR; PREVIDIA-VOXD**
Trademark: **INIM**
Other information: **See ANNEX**

Produced by:
INIM ELECTRONICS S.r.l.
Via Dei Lavoratori 10 – Frazione Centobuchi
63076 Montepandone (AP), Italy

in the manufacturing plant:
PI.H0000J

This Certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 54-4:1997 + A1:2002 + A2:2006;
EN 54-16:2008**

Under system **1** are applied and that **the product fulfills all the prescribed requirements set out above**

ISSUED ON 01/09/2022

REVISION 0

B.U. PRODUCT CONFORMITY ASSESSMENT
CPR TECHNICAL DIRECTOR
(ENG. VALBERTO BAGGIO)

This certificate was first issued on 01/09/2022 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the products, and the manufacturing conditions in the plant are not modified significantly.

This Certificate was issued by IMQ S.p.A., a Notified Body according to Regulation (EU) No. 305/2011. IMQ S.p.A. Identification Number is: **0051**. This certificate is subjected to the Regulation of Assessment and Verification of Constancy of Performance of the Construction Products as Notified Body, according to Regulation (EU) no. 305/2011 and Legislative Decree n.106/ 2017 (REG. ON / CPR)

ANNEX

0051-CPR-2827

Model **PREVIDIA-VOX**

Configuration:

The equipment is contained in a standard grey metal enclosure (dimensions: 675 x 430 x 250 mm) with IP30 degree of protection.

Internally it is fitted with the following main parts fully configurable in multiple enclosures, extendable up to 4 adjacent one above the other:

- No. 1 CPU module type FPAMIAS with integrated alphanumeric touch LCD;
- No. 1 Voice Alarm Control and Indicating module type IFAMEVAC;
- No. 2 Amplifier module type IFAMAMP rated 250 W / 40 Ω (with PU type IFAMPSU) or 80 W / 125 Ω (with PU type IFM24160), up to 30 maximum;
- No. 1 Local Audio module type IAS-ADAPT1000;
- No. 1 Outputs module type IFM4R, with 4 relays, up to 16 maximum for equipment;
- No. 1 Inputs/outputs module type IFM4IO, with 4 input/output circuits, up to 16 maximum for equipment;
- No. 1 Inputs/outputs module type IFM16IO, with 16 input/output circuits, up to 4 maximum for equipment;
- No. 1 Local microphone type IPG-PTT;
- No. 1 LED module type FPMLED, up to 7 maximum for equipment;
- No. 1 Module for hornet network connection type IFMNET, up to 1 maximum for equipment;
- No. 1 Module for audio network connection type IFAMIDANET, up to 1 maximum for equipment;
- No. 1 CANDRIVE+ board;
- No. 1 Switching Power Unit trademark INIM, type IFAMPSU composed of the control board and the switching power supply trademark MEAN WELL type PSPA-1000-24, rated 27.6 V – 32 A or 38 A with No. 2 Allocable batteries rated 12 V – 38 Ah or 24 Ah or 17 Ah, or
- No. 1 Switching Power Unit trademark INIM, type IFM24160, rated 27.6 V – 5.2 A with No. 2 Allocable batteries rated 12 V – 24 Ah or 17 Ah.

The equipment is also provided with the following external devices:

- Emergency microphone base trademark INIM, type IPGE06;
- Emergency microphone base trademark INIM, type IPGE18;
- Stem microphone type IPG-GOOSENECK

This Certificate was issued by IMQ S.p.A., a Notified Body according to Regulation (EU) No. 305/2011. IMQ S.p.A. Identification Number is: **0051**. This certificate is subjected to the Regulation of Assessment and Verification of Constancy of Performance of the Construction Products as Notified Body, according to Regulation (EU) no. 305/2011 and Legislative Decree n.106/ 2017 (REG. ON / CPR)

Models **PREVIDIA-VOXR; PREVIDIA-VOXD**

Configuration:

As model PREVIDIA-VOX but with a different color of the enclosure.

- "R" Red;
- "D" Dark Grey.

Technical Characteristics

- Hardware identification of the microcontroller (U1) used on the CPU module type FPAMIAS:
NXP, LPC1788FBD208;
- Firmware identification of the microcontroller (U1) used on the CPU module type FPAMIAS: 1.00.

List of optional functions with requirements (EN 54-16)

- 7.3 Audible warning
- 7.5 Phased evacuation
- 7.6.2 Manual silencing of the voice alarm condition
- 7.7.2 Manual reset of the voice alarm condition
- 7.8 Output to fire alarm devices
- 7.9 Voice alarm condition output
- 8.3 Indication of faults related to the transmission path to the CIE
- 8.4 Indication of faults related to voice alarm zones
- 9 Disablement condition
- 10 Voice alarm manual control
- 12 Emergency microphone(s)
- 13.14 Redundant power amplifiers

This Certificate was issued by IMQ S.p.A., a Notified Body according to Regulation (EU) No. 305/2011. IMQ S.p.A. Identification Number is: **0051**. This certificate is subjected to the Regulation of Assessment and Verification of Constancy of Performance of the Construction Products as Notified Body, according to Regulation (EU) no. 305/2011 and Legislative Decree n.106/ 2017 (REG. ON / CPR)